

**North Texas Municipal Water District
Water Analysis
May-2009**

Mineral Analysis	Raw	Treated	Standards			
			EPA Primary	EPA Secondary	TCEQ Primary	TCEQ Secondary
	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Residue on Evaporation	268	326		500		1000
Silica (SiO ₂)	5.35	4.48				
Iron (Fe)	0.669	<0.200		0.3		0.3
Calcium (Ca)	56.0	64.9				
Magnesium (Mg)	5.26	5.34				
Sodium (Na)	36.4	47.9				
Potassium (K)	4.72	4.93				
Bicarbonates (HCO ₃)	143	103				
Carbonates (CO ₃)	0	0				
Hydroxides (OH)	0	0				
Sulfate (SO ₄)	42.9	76.2		250		
Nitrite (NO ₂)	<0.0200	<0.0200	1		1	
Nitrate (NO ₃)	0.649	0.667	10		10	
Chloride (Cl)	31.4	35.8		250		300
Fluoride (F)	0.272	0.568	4.0	2.0		2.0
Phosphates (PO ₄)	0.0530	<0.0200				

	(mg/L as CaCO₃)	(mg/L as CaCO₃)	(mg/L as CaCO₃)	(mg/L as CaCO₃)	(mg/L as CaCO₃)	(mg/L as CaCO₃)
Total Alkalinity	117	84.4				
Phenolphthalein Alkalinity	0	0				
Noncarbonate Hardness	63.3	107				
Total Hardness	180	191				
Langelier Index	-	[- 0.790]				

Trace Element Analysis

	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Arsenic (As)	<0.00500	<0.00500	0.01		0.01	
Barium (Ba)	0.0586	0.0461	2		2	
Cadmium (Cd)	<0.00100	<0.00100	0.005		0.005	
Chromium (Cr)	<0.00500	<0.00500	0.1		0.1	
Copper (Cu)	0.00640	0.0495	1.3		1.3	1.0
Iron (Fe)	0.669	<0.200		0.3		
Lead (Pb)	<0.00100	<0.00100	0.15		0.15	
Manganese (Mn)	0.0374	0.00257		0.05		0.05
Mercury (Hg)	<0.000100	<0.000100	0.002		0.002	
Nickel (Ni)	0.00385	0.00324				
Selenium (Se)	<0.00100	<0.00100	0.05		0.05	
Silver (Ag)	<0.00100	<0.00100		0.10		0.1
Zinc (Zn)	<0.0100	<0.0100		5		5

Other Analysis

Chlorine Residual (mg/L)	-	2.87*	4.0		4.0	
Total coliform (Present / Absent)	P	A	A		A	
pH (Standard Units) @ 25°C	7.64*	6.93*		6.5 - 8.5		>7.0
Specific Conductance (Umhos)	485	566				
Turbidity (NTU)	25.9	0.147*	0.3		0.3	
Threshold Odor Number	4F	1E				3

Note 1: National Primary Drinking Water Regulations or Primary Standards are legally enforceable standards. National Secondary Drinking Water Regulations or Secondary Standards are non-enforceable guidelines regulating contaminants that may cause cosmetic or aesthetic effects In Drinking Water.

Note 2: TCEQ Primary Standards are the maximum contaminant level allowed for each constituent. TCEQ Primary Standards are legally enforceable standards.

Note 3: * Identifies Monthly Average Process analyses.