

** NORTH TEXAS MUNICIPAL WATER DISTRICT - Tawakoni
Water Analysis
Apr-2020

<u>Mineral Analysis</u>	<u>Raw</u>	<u>Treated</u>	<u>Standards</u>			
			<u>EPA</u>	<u>EPA</u>	<u>TCEQ</u>	<u>TCEQ</u>
	(mg/L)	(mg/L)	<u>Primary</u>	<u>Secondary</u>	<u>Primary</u>	<u>Secondary</u>
			(mg/L)	(mg/L)	(mg/L)	(mg/L)
Residue on Evaporation	109	187		500		1000
Silica (SiO2)	4.17	3.96				
Iron (Fe)	0.306	<0.200		0.3		0.3
Calcium (Ca)	24.7	37.6				
Magnesium (Mg)	2.26	2.63				
Sodium (Na)	7.60	14.5				
Potassium (K)	3.34	3.42				
Sulfate (SO4)	9.39	62.0		250		
Nitrite (NO2)	<0.0200	<0.0200	1		1	
Nitrate (NO3)	0.411	0.530	10		10	
Chloride (Cl)	5.0	15.1		250		300
Fluoride (F)	0.137	0.339	4.0	2.0	4	2.0
Phosphates (PO4)	0.0510	0.0160				
	(mg/L as CaCO3)	(mg/L as CaCO3)	(mg/L as CaCO3)	(mg/L as CaCO3)	(mg/L as CaCO3)	(mg/L as CaCO3)
Total Alkalinity	74.0 *	55.0 *				
Total Hardness	71.6	106				
Langelier Index		--				

Trace Element Analysis

	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Arsenic (As)	0.00115	<0.00050	0.01		0.01	
Barium (Ba)	0.0583	0.0592	2		2	
Cadmium (Cd)	<0.00100	<0.00100	0.005		0.005	
Chromium (Cr)	<0.00250	<0.00250	0.1		0.1	
Copper (Cu)	0.00199	0.0117	1.3	1	1.3	1.0
Iron (Fe)	0.306	<0.200		0.3		0.3
Lead (Pb)	<0.000500	<0.000500	0.015		0.015	
Manganese (Mn)	0.0148	0.00400		0.05		0.05
Mercury (Hg)	<0.000100	<0.000100	0.002		0.002	
Nickel (Ni)	0.00170	0.00480				
Selenium (Se)	<0.00100	<0.00100	0.05		0.05	
Silver (Ag)	<0.00050	<0.00050		0.10		0.1
Zinc (Zn)	0.00265	<0.00250		5		5

Other Analysis

Chlorine Residual (mg/L)	--	3.75 *	4.0		4.0	
Total coliform (Present / Absent)	--	A	A		A	
pH (Standard Units) @ 25°C	--	8.10 *		6.5 - 8.5		>7.0
Specific Conductance (Umhos)	186	312				
Turbidity (NTU)	5.2 *	0.05 *	0.3		0.3	
Threshold Odor Number	3.0	3.0				3

Note 1: National Primary Drinking Water Regulations or Primary Standards are legally enforceable standards. National Secondary Drinking Water Regulations or Secondary Standards are non-enforceable guidelines regulating contaminants that may cause cosmetic or aesthetic effects In Drinking Water.

Note 2: TCEQ Primary Standards are the maximum contaminant level allowed for each constituent. TCEQ Primary Standards are legally enforceable standards.

Note 3: * Identifies Monthly Average Process analyses. ** No odor analysis performed.