

NORTH TEXAS MUNICIPAL WATER DISTRICT - Bonham
Water Analysis
Mar-2020

Mineral Analysis	Raw	Treated	Standards			
			EPA Primary	EPA Secondary	TCEQ Primary	TCEQ Secondary
	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Residue on Evaporation	111	192		500		1000
Silica (SiO ₂)	<2.00	<2.00				
Iron (Fe)	2.18	0.206		0.3		0.3
Calcium (Ca)	10.4	46.6				
Magnesium (Mg)	1.62	1.85				
Sodium (Na)	3.47	11.2				
Potassium (K)	3.10	2.83				
Sulfate (SO ₄)	3.74	68.7		250		
Nitrite (NO ₂)	<0.0200	<0.0200	1		1	
Nitrate (NO ₃)	<0.0500	0.104	10		10	
Chloride (Cl)	6.18	16.4		250		300
Fluoride (F)	0.0700	0.528	4.0	2.0	4	2.0
Phosphates (PO ₄)	0.155	0.0130				
	(mg/L as CaCO ₃)	(mg/L as CaCO ₃)	(mg/L as CaCO ₃)	(mg/L as CaCO ₃)	(mg/L as CaCO ₃)	(mg/L as CaCO ₃)
Total Alkalinity	42.8 *	69.1 *				
Total Hardness	44.6	119				
Langelier Index	--	--				

Trace Element Analysis

	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Arsenic (As)	0.00124	<0.00050	0.01		0.01	
Barium (Ba)	0.0541	0.0436	2		2	
Cadmium (Cd)	<0.00100	<0.00100	0.005		0.005	
Chromium (Cr)	0.00252	<0.00250	0.1		0.1	
Copper (Cu)	0.00406	0.00298	1.3	1	1.3	1.0
Iron (Fe)	2.18	0.206		0.3		0.3
Lead (Pb)	0.00158	<0.000500	0.015		0.015	
Manganese (Mn)	0.0852	0.00690		0.05		0.05
Mercury (Hg)	<0.000100	<0.000100	0.002		0.002	
Nickel (Ni)	0.00221	0.00383				
Selenium (Se)	<0.00100	<0.00100	0.05		0.05	
Silver (Ag)	<0.00050	<0.00050		0.10		0.1
Zinc (Zn)	0.00599	<0.00250		5		5

Other Analysis

Chlorine Residual (mg/L)	--	2.51	4.0		4.0	
Total coliform (Present / Absent)	--	A	A		A	
pH (Standard Units) @ 25°C	7.08 *	7.89 *		6.5 - 8.5		>7.0
Specific Conductance (Umhos)	90.8	321				
Turbidity (NTU)	46.8 *	0.07 *	0.3		0.3	
Threshold Odor Number	8.0	2.0				3

Note 1: National Primary Drinking Water Regulations or Primary Standards are legally enforceable standards. National Secondary Drinking Water Regulations or Secondary Standards are non-enforceable guidelines regulating contaminants that may cause cosmetic or aesthetic effects In Drinking Water.

Note 2: TCEQ Primary Standards are the maximum contaminant level allowed for each constituent. TCEQ Primary Standards are legally enforceable standards.

Note 3: * Identifies Monthly Average Process analyses. ** No odor analysis performed.