NORTH TEXAS MUNICIPAL WATER DISTRICT - Tawakoni Water Analysis Mar-2019

Mineral Analysis	Raw	Treated	<u>Standards</u>			
			EPA Primary	EPA Secondary	TCEQ Primary	TCEQ Secondary
	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Residue on Evaporation	90.0	147		500		1000
Silica (SiO2)	3.86	3.71				
Iron (Fe)	0.529	0.286		0.3		0.3
Calcium (Ca)	24.3	36.8				
Magnesium (Mg)	2.58	2.62				
Sodium (Na)	7.59	12.4				
Potassium (K)	3.86	3.66				
Sulfate (SO4)	8.47	50.1		250		
Nitrite (NO2)	<0.0200	<0.0200	1		1	
Nitrate (NO3)	0.428	0.446	10		10	
Chloride (CI)	4.6	9.2		250		300
Fluoride (F)	0.137	0.287	4.0	2.0	4	2.0
Phosphates (PO4)	0.0630	<0.0100			<u> </u>	
. , , ,	(mg/L as CaCO3)					
Total Alkalinity	74.4 *	59.5 *				
Total Hardness	68.4	99.8				
Langelier Index		-2.2053				
Trace Element Analysis	l					1
	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Arsenic (As)	0.00137	<0.00050	0.01		0.01	
Barium (Ba)	0.0607	0.0519	2		2	
Cadmium (Cd)	<0.00100	<0.00100	0.005		0.005	
Chromium (Cr)	<0.00250	<0.00250	0.1		0.1	
Copper (Cu)	0.00113	0.0116	1.3	1	1.3	1.0
Iron (Fe)	0.529	0.286		0.3		0.3
Lead (Pb)	<0.000500	<0.000500	0.015		0.015	
Manganese (Mn)	0.0279	0.00305		0.05		0.05
Mercury (Hg)	<0.000100	<0.000100	0.002		0.002	
Nickel (Ni)	0.00236	0.00574				
Selenium (Se)	<0.00100	<0.00100	0.05		0.05	
Silver (Ag)	<0.00050	<0.00050		0.10		0.1
Zinc (Zn)	<0.00250	<0.00250		5		5
Other Analysis		1	1			1
Chlorine Residual (mg/L)		3.57 *	4.0		4.0	
Total coliform (Present / Absent)		Α	Α		Α	
pH (Standard Units) @ 25°C	7.80	8.10 *		6.5 - 8.5		>7.0
Specific Conductance (Umhos)	175	270				
Turbidity (NTU)	16.4 *	0.04 *	0.3		0.3	
Threshold Odor Number	2.0	2.0				3

Note 1: National Primary Drinking Water Regulations or Primary Standards are legally enforceable standards. National Secondary Drinking Water Regulations or Secondary Standards are non-enforceable guidelines regulating contaminants that may cause cosmetic or aesthetic effects In Drinking Water.

Note 2: TCEQ Primary Standards are the maximum contaminant level allowed for each constituent. TCEQ Primary Standards are legally enforceable standards.

Note 3: * Identifies Monthly Average Process analyses. ** No odor analysis performed.