

NORTH TEXAS MUNICIPAL WATER DISTRICT - Wylie

Water Analysis

Apr-2019

Mineral Analysis	Raw	Treated	Standards			
			EPA Primary	EPA Secondary	TCEQ Primary	TCEQ Secondary
	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Residue on Evaporation	290	358		500		1000
Silica (SiO2)	3.73	3.08				
Iron (Fe)	0.581	0.356		0.3		0.3
Calcium (Ca)	76.0	69.0				
Magnesium (Mg)	6.00	6.37				
Sodium (Na)	30.9	62.6				
Potassium (K)	3.91	3.79				
Sulfate (SO4)	42.4	101		250		
Nitrite (NO2)	<0.0100	<0.0100	1		1	
Nitrate (NO3)	0.705	0.874	10		10	
Chloride (Cl)	33.3	42.9		250		300
Fluoride (F)	0.225	0.256 *	4.0	2.0	4.0	2.0
Phosphates (PO4)	0.0750	0.0110				

	(mg/L as CaCO3)	(mg/L as CaCO3)	(mg/L as CaCO3)	(mg/L as CaCO3)	(mg/L as CaCO3)	(mg/L as CaCO3)
Total Alkalinity	144 *	117 *				
Total Hardness	174	179				
Langelier Index		0.4245				

Trace Element Analysis

	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Arsenic (As)	0.00144	0.00037	0.01		0.01	
Barium (Ba)	0.0611	0.0562	2		2	
Cadmium (Cd)	<0.000500	<0.000500	0.005		0.005	
Chromium (Cr)	<0.00125	<0.00125	0.1		0.1	
Copper (Cu)	0.0136	0.00328	1.3	1	1.3	1.0
Iron (Fe)	0.581	0.356		0.3		0.3
Lead (Pb)	0.000302	<0.000250	0.015		0.015	
Manganese (Mn)	0.0205	0.0133		0.05		0.05
Mercury (Hg)	<0.0000500	<0.0000500	0.002		0.002	
Nickel (Ni)	0.00322	0.00620				
Selenium (Se)	0.000540	<0.000500	0.05		0.05	
Silver (Ag)	<0.000250	<0.000250		0.10		0.1
Zinc (Zn)	0.00570	0.00536		5		5

Other Analysis

Chlorine Residual (mg/L)	--	3.75 *	4.0		4.0	
Total coliform (Present / Absent)	--	A *	A		A	
pH (Standard Units) @ 25°C	8.41 *	8.32 *		6.5 - 8.5		>7.0
Specific Conductance (Umhos)	508 *	631 *				
Turbidity (NTU)	13.7 *	0.0662 *	0.3		0.3	
Threshold Odor Number	17.0	1.0				3

Note 1: National Primary Drinking Water Regulations or Primary Standards are legally enforceable standards. National Secondary Drinking Water Regulations or Secondary Standards are non-enforceable guidelines regulating contaminants that may cause cosmetic or aesthetic effects In Drinking Water.

Note 2: TCEQ Primary Standards are the maximum contaminant level allowed for each constituent. TCEQ Primary Standards are legally enforceable standards.

Note 3: * Identifies Monthly Average Process analyses.