

** NORTH TEXAS MUNICIPAL WATER DISTRICT - Tawakoni
 Water Analysis
 Oct-2020

<u>Mineral Analysis</u>	<u>Raw</u>	<u>Treated</u>	<u>Standards</u>			
			<u>EPA Primary</u>	<u>EPA Secondary</u>	<u>TCEQ Primary</u>	<u>TCEQ Secondary</u>
	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Residue on Evaporation	176	258		500		1000
Silica (SiO2)	3.68	3.36				
Iron (Fe)	<0.200	0.253		0.3		0.3
Calcium (Ca)	24.7	40.7				
Magnesium (Mg)	2.33	2.57				
Sodium (Na)	8.94	14.4				
Potassium (K)	3.59	3.71				
Sulfate (SO4)	8.49	66.4		250		
Nitrite (NO2)	<0.0200	<0.0200	1		1	
Nitrate (NO3)	0.362	0.439	10		10	
Chloride (Cl)	5.9	14.7		250		300
Fluoride (F)	0.169	0.526	4.0	2.0	4	2.0
Phosphates (PO4)	0.0610	<0.0100				
	(mg/L as CaCO3)	(mg/L as CaCO3)	(mg/L as CaCO3)	(mg/L as CaCO3)	(mg/L as CaCO3)	(mg/L as CaCO3)
Total Alkalinity	79.5 *	58.0 *				
Total Hardness	73.0	111				
Langelier Index		-0.3980				

Trace Element Analysis

	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Arsenic (As)	0.00230	<0.00050	0.01		0.01	
Barium (Ba)	0.0742	0.0612	2		2	
Cadmium (Cd)	<0.00100	<0.00100	0.005		0.005	
Chromium (Cr)	<0.00250	<0.00250	0.1		0.1	
Copper (Cu)	<0.00100	0.0305	1.3	1	1.3	1.0
Iron (Fe)	<0.200	0.253		0.3		0.3
Lead (Pb)	<0.000500	<0.000500	0.015		0.015	
Manganese (Mn)	0.0212	0.00629		0.05		0.05
Mercury (Hg)	<0.000100	<0.000100	0.002		0.002	
Nickel (Ni)	0.00150	0.00480				
Selenium (Se)	<0.00100	<0.00100	0.05		0.05	
Silver (Ag)	<0.00050	<0.00050		0.10		0.1
Zinc (Zn)	<0.00250	<0.00250		5		5

Other Analysis

Chlorine Residual (mg/L)	--	3.59 *	4.0		4.0	
Total coliform (Present / Absent)	--	A	A		A	
pH (Standard Units) @ 25°C	7.60	7.70 *		6.5 - 8.5		>7.0
Specific Conductance (Umhos)	192	310				
Turbidity (NTU)	3.1 *	0.03 *	0.3		0.3	
Threshold Odor Number	3.0	1.0				3

Note 1: National Primary Drinking Water Regulations or Primary Standards are legally enforceable standards. National Secondary Drinking Water Regulations or Secondary Standards are non-enforceable guidelines regulating contaminants that may cause cosmetic or aesthetic effects In Drinking Water.

Note 2: TCEQ Primary Standards are the maximum contaminant level allowed for each constituent. TCEQ Primary Standards are legally enforceable standards.

Note 3: * Identifies Monthly Average Process analyses. ** No odor analysis performed.