

**NORTH TEXAS MUNICIPAL WATER DISTRICT - Wylie**

**Water Analysis**

**Feb-2021**

<u>Mineral Analysis</u>	<u>Raw</u> (mg/L)	<u>Treated</u> (mg/L)	<u>Standards</u>			
			<u>EPA</u> <u>Primary</u> (mg/L)	<u>EPA</u> <u>Secondary</u> (mg/L)	<u>TCEQ</u> <u>Primary</u> (mg/L)	<u>TCEQ</u> <u>Secondary</u> (mg/L)
			Residue on Evaporation	241	358	
Silica (SiO2)	7.28	4.88				
Iron (Fe)	0.410	0.231		0.3		0.3
Calcium (Ca)	45.7	56.4				
Magnesium (Mg)	3.13	5.84				
Sodium (Na)	22.8	52.9				
Potassium (K)	4.31	4.47				
Sulfate (SO4)	38.2	109		250		
Nitrite (NO2)	<0.0100	<0.0100	1		1	
Nitrate (NO3)	0.680	0.716	10		10	
Chloride (Cl)	23.5	50.4		250		300
Fluoride (F)	0.260	0.322 *	4.0	2.0	4.0	2.0
Phosphates (PO4)	0.0680	0.0100				

	(mg/L as CaCO3)	(mg/L as CaCO3)	(mg/L as CaCO3)	(mg/L as CaCO3)	(mg/L as CaCO3)	(mg/L as CaCO3)
Total Alkalinity	122 *	100 *				
Total Hardness	134	160				
Langelier Index		0.3927				

**Trace Element Analysis**

	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Arsenic (As)	0.00137	0.00058	0.01		0.01	
Barium (Ba)	0.0432	0.0440	2		2	
Cadmium (Cd)	<0.000500	<0.000500	0.005		0.005	
Chromium (Cr)	<0.00125	<0.00125	0.1		0.1	
Copper (Cu)	0.00492	0.00263	1.3	1	1.3	1.0
Iron (Fe)	0.410	0.231		0.3		0.3
Lead (Pb)	0.000314	<0.000250	0.015		0.015	
Manganese (Mn)	0.0339	0.00692		0.05		0.05
Mercury (Hg)	<0.0000500	<0.0000500	0.002		0.002	
Nickel (Ni)	0.00368	0.00682				
Selenium (Se)	0.000514	<0.000500	0.05		0.05	
Silver (Ag)	<0.000250	<0.000250		0.10		0.1
Zinc (Zn)	0.00532	0.00395		5		5

**Other Analysis**

Chlorine Residual (mg/L)	--	3.48 *	4.0		4.0	
Total coliform ( Present / Absent )	--	A *	A		A	
pH (Standard Units) @ 25°C	8.34 *	8.31 *		6.5 - 8.5		>7.0
Specific Conductance (Umhos)	399 *	598 *				
Turbidity (NTU)	11.5 *	0.0654 *	0.3		0.3	
Threshold Odor Number	3.0	3.0				3

**Note 1: National Primary Drinking Water Regulations or Primary Standards are legally enforceable standards. National Secondary Drinking Water Regulations or Secondary Standards are non-enforceable guidelines regulating contaminants that may cause cosmetic or aesthetic effects In Drinking Water.**

**Note 2: TCEQ Primary Standards are the maximum contaminant level allowed for each constituent. TCEQ Primary Standards are legally enforceable standards.**

**Note 3: \* Identifies Monthly Average Process analyses.**