

** NORTH TEXAS MUNICIPAL WATER DISTRICT - Tawakoni
 Water Analysis
 Mar-2021

<u>Mineral Analysis</u>	<u>Raw</u>	<u>Treated</u>	<u>Standards</u>			
			<u>EPA Primary</u>	<u>EPA Secondary</u>	<u>TCEQ Primary</u>	<u>TCEQ Secondary</u>
	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Residue on Evaporation	142	193		500		1000
Silica (SiO2)	4.04	4.05				
Iron (Fe)	0.370	<0.200		0.3		0.3
Calcium (Ca)	26.4	44.1				
Magnesium (Mg)	2.62	2.76				
Sodium (Na)	11.4	15.6				
Potassium (K)	3.73	3.74				
Sulfate (SO4)	9.48	57.2		250		
Nitrite (NO2)	<0.0200	<0.0200	1		1	
Nitrate (NO3)	0.412	0.438	10		10	
Chloride (Cl)	5.5	12.2		250		300
Fluoride (F)	0.150	0.309	4.0	2.0	4	2.0
Phosphates (PO4)	0.0490	0.0100				
	(mg/L as CaCO3)	(mg/L as CaCO3)	(mg/L as CaCO3)	(mg/L as CaCO3)	(mg/L as CaCO3)	(mg/L as CaCO3)
Total Alkalinity	77.4 *	66.0 *				
Total Hardness	74.0	100				
Langelier Index		-0.1688				

Trace Element Analysis

	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Arsenic (As)	0.00109	<0.00050	0.01		0.01	
Barium (Ba)	0.0615	0.0518	2		2	
Cadmium (Cd)	<0.00100	<0.00100	0.005		0.005	
Chromium (Cr)	<0.00250	<0.00250	0.1		0.1	
Copper (Cu)	<0.00100	0.0114	1.3	1	1.3	1.0
Iron (Fe)	0.370	<0.200		0.3		0.3
Lead (Pb)	<0.000500	<0.000500	0.015		0.015	
Manganese (Mn)	0.0149	0.00326		0.05		0.05
Mercury (Hg)	<0.000100	<0.000100	0.002		0.002	
Nickel (Ni)	0.00152	0.00467				
Selenium (Se)	<0.00100	<0.00100	0.05		0.05	
Silver (Ag)	<0.00050	<0.00050		0.10		0.1
Zinc (Zn)	<0.00250	<0.00250		5		5

Other Analysis

Chlorine Residual (mg/L)	--	3.89 *	4.0		4.0	
Total coliform (Present / Absent)	--	A	A		A	
pH (Standard Units) @ 25°C	7.80	8.10 *		6.5 - 8.5		>7.0
Specific Conductance (Umhos)	200	302				
Turbidity (NTU)	7.2 *	0.06 *	0.3		0.3	
Threshold Odor Number	1.0	**				3

Note 1: National Primary Drinking Water Regulations or Primary Standards are legally enforceable standards. National Secondary Drinking Water Regulations or Secondary Standards are non-enforceable guidelines regulating contaminants that may cause cosmetic or aesthetic effects In Drinking Water.

Note 2: TCEQ Primary Standards are the maximum contaminant level allowed for each constituent. TCEQ Primary Standards are legally enforceable standards.

Note 3: * Identifies Monthly Average Process analyses. ** No odor analysis performed.