

NORTH TEXAS MUNICIPAL WATER DISTRICT - Bonham

Water Analysis

Dec-2021

Mineral Analysis	Raw	Treated	Standards			
			EPA Primary	EPA Secondary	TCEQ Primary	TCEQ Secondary
	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Residue on Evaporation	102	213		500		1000
Silica (SiO ₂)	4.03	4.00				
Iron (Fe)	0.514	0.298		0.3		0.3
Calcium (Ca)	19.0	74.0				
Magnesium (Mg)	2.54	2.67				
Sodium (Na)	5.11	13.9				
Potassium (K)	3.82	3.86				
Sulfate (SO ₄)	2.09	74.5		250		
Nitrite (NO ₂)	<0.0200	<0.0200	1		1	
Nitrate (NO ₃)	<0.0500	0.135	10		10	
Chloride (Cl)	4.28	15.0		250		300
Fluoride (F)	0.111	0.292	4.0	2.0	4	2.0
Phosphates (PO ₄)	0.0640	<0.0100				
	(mg/L as CaCO₃)	(mg/L as CaCO₃)	(mg/L as CaCO₃)	(mg/L as CaCO₃)	(mg/L as CaCO₃)	(mg/L as CaCO₃)
Total Alkalinity	75.0 *	78.5 *				
Total Hardness	60.0	124				
Langelier Index	--	-0.262				

Trace Element Analysis

	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Arsenic (As)	0.00237	0.00111	0.01		0.01	
Barium (Ba)	0.0727	0.0528	2		2	
Cadmium (Cd)	<0.00100	<0.00100	0.005		0.005	
Chromium (Cr)	<0.00250	<0.00250	0.1		0.1	
Copper (Cu)	0.00433	0.00264	1.3	1	1.3	1.0
Iron (Fe)	0.514	0.298		0.3		0.3
Lead (Pb)	0.00187	<0.000500	0.015		0.015	
Manganese (Mn)	0.183	0.00524		0.05		0.05
Mercury (Hg)	<0.000100	<0.000100	0.002		0.002	
Nickel (Ni)	0.00148	0.00442				
Selenium (Se)	<0.00100	<0.00100	0.05		0.05	
Silver (Ag)	<0.00050	<0.00050		0.10		0.1
Zinc (Zn)	<0.00250	<0.00250		5		5

Other Analysis

Chlorine Residual (mg/L)	--	3.18	4.0		4.0	
Total coliform (Present / Absent)	--	A	A		A	
pH (Standard Units) @ 25°C	7.66 *	7.90 *		6.5 - 8.5		>7.0
Specific Conductance (Umhos)	140	321				
Turbidity (NTU)	12.0 *	0.07 *	0.3		0.3	
Threshold Odor Number	6	2				3

Note 1: National Primary Drinking Water Regulations or Primary Standards are legally enforceable standards. National Secondary Drinking Water Regulations or Secondary Standards are non-enforceable guidelines regulating contaminants that may cause cosmetic or aesthetic effects In Drinking Water.

Note 2: TCEQ Primary Standards are the maximum contaminant level allowed for each constituent. TCEQ Primary Standards are legally enforceable standards.

Note 3: * Identifies Monthly Average Process analyses. ** No odor analysis performed.